

Fire Department Comments (Revised)

1. Emergency Housing Facility. The Emergency Housing Facility shall conform to the following fire requirements

- a. There shall be no open fires. Cooking fires shall be pre-approved by the Olympia Fire Department;
- b. No heating appliances within the individual units are allowed without pre-approval by the Olympia Fire Department;
- c. No cooking appliances, other than microwave appliances, are allowed in individual units;
- d. An adequate number, with appropriate rating, of fire extinguishers shall be provided as approved by the Olympia Fire Department;
- e. Adequate access for fire and emergency medical apparatus shall be provided. This shall be determined by the Olympia Fire Department;
- f. Adequate separation aisles of 6' shall be maintained for gurney and firefighter access and 6' separation shall be maintained from fences and property lines. Separation between individual units on the site shall be determined on a site specific visit by the Olympia Building and Fire Departments.
- g. Electrical service shall be in accordance with recognized and accepted practice and codes.
- h. There shall be an address associated to the site for emergency reporting and response. The address shall be posted and readily visible on approach.
- i. The site shall remain clear of physical, environmental, biological, or medical waste that could be a health hazard to tenants and emergency responders.
- j. There shall be no smoking inside of units.